

zkratovna

Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

INDEPENDENT TESTING LABORATORY, ACCREDITED ACCORDING TO ČSN EN ISO/IEC 17025
BY THE ČESKÝ INSTITUT PRO AKREDITACI, O.P.S., UNDER THE NUMBER 1035

C E R T I F I C A T E

OF TYPE TEST No. 08 - 110

Test object : Low-voltage switchgear and controlgear assembly
Type : ELMO-R
Serial No. : 3010.211.1

Ratings
Rated voltage : 3 x 230 V / 400 V
Rated current : 2500 A
Rated frequency : 50 Hz

Manufacturer : ELMO spol. s r.o.
Příluky 386, 760 01 Zlín, Czech Republic

Customer : ELMO spol. s r.o.
Příluky 386, 760 01 Zlín, Czech Republic

Date of test : 22.10. 2008

The test object produced in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the type tests in accordance with the mentioned Standard :

ČSN EN 60439-1/2000, čl. 8.2.1

The results are shown in the tables and the record of proving tests attached hereto.

◆ **Interpretation of results :**

The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on sheet 3 and 4.

The test results apply only to the specific piece of apparatus tested from the particular place of manufacture. The responsibility for conformity of any product having the same designation with that tested rests with the manufacturer.

This document can not substitute the product Certificate according to ČSN EN 45 011.

ONLY INTEGRAL REPRODUCTION OF THIS CERTIFICATE, OR REPRODUCTIONS OF THIS SHEET ACCOMPANIED BY ANY SHEETS ON WHICH ARE STATED THE ENDORSED RATINGS OF THE APPARATUS TESTED, ARE PERMITTED WITHOUT WRITTEN PERMISSION FROM TESTING LABORATORY ZKRATOVNA.

Copy No.: E

Praha 9, Běchovice

23. 1. 2009

Tested by:

P.P. Abrahámčík
Richard Abrahámčík



Vladimír Mastný
Vladimír Mastný
Head of the Laboratory



e-version